




Ref: 2026D099705

9 October 2026



Regulation and Compliance


Office of the
Technical Regulator

Level 8, 11 Waymouth Street
Adelaide SA 5000

GPO Box 618
Adelaide SA 5001

Telephone: 08 8226 5500
Facsimile: 08 8226 5866

www.otr.sa.gov.au

Dear 

RE: Tailem Power Precinct Project

The development of the Tailem Power Precinct project has been assessed by the Office of the Technical Regulator (OTR) under section 122 of the *Planning, Development and Infrastructure Act 2016*.

The *Planning, Development and Infrastructure (General) Regulations 2017* prescribe if the proposed development is for the purposes of the provision of electricity generating plant with a generating capacity of more than 5 MW that is to be connected to the State's power system – a certificate from the Technical Regulator is required, certifying that the proposed development complies with the requirements of the Technical Regulator in relation to the security and stability of the State's power system.

In deciding on your application, I have taken the following information into account:

- TPP-PLA-RPT-003_OTR_Generator_Certificate_rC.pdf
- TPP-PLA-RPT-003_OTR_Generator_Certificate_rD.pdf

After assessing the information provided, I advise that approval is granted on the condition that the synchronous machines will provide a minimum of 537MW.s of real inertia, and 3.9MW of fast frequency response shall be provided via the BESS.

Should you have any questions regarding this matter, please do not hesitate to call Mark Burns on (08) 8429 2707.

Yours sincerely



Rob Faunt
TECHNICAL REGULATOR

Regulation and Compliance

Level 8, 11 Waymouth Street Adelaide SA 5000 | GPO Box 618 Adelaide SA 5001 | DX541
Tel (+61) 8 8226 5500 | Fax (+61) 8 8226 5866 | www.otr.sa.gov.au | ABN 83 524 915 929